

Type test Certificate of short-circuit and dielectric performance

Transformers & Rectifiers Ltd.

Surrey, United Kingdom

has successfully passed the type test sequence on a three-phase

oil-immersed earthing / distribution transformer

Type: E21/1

Rating: 500 kVA – 11 kV – $\pm 2 \times 2,5\%$ / 0,433 kV – Znyn1 – 50 Hz

The test object passed the specification of test duties of

IEC 60076-5

IEC 60076-6

The test results are recorded in Certificate No.

TDT 2193-10

This Certificate is issued on 18 February 2011

KEMA Nederland B.V.



P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

