



Acceptance NST
Engineering Directorate
40 Melton Street
London
NW1 2EE

IMPORTANT INFORMATION FOR USERS

From: Acceptance Specialist

Tel: 085 78423 (0207 557 8423)
Fax: 085 79013 (0207 557 9013)
Email: peter.anderson@networkrail.co.uk

Date: 14.03.06

Product Acceptance Advice Note

This advice note provides appropriate background information and any specific action that may be required in accordance with the **attached certificate**. It will enable you to meet your obligations in meeting the requirements of the Company procedure RT/LS/P/029.

Certificate Ref.	Issue	Product
PA05/01793	1	Substation Auxiliary Transformers

Manufacturer

Transformers & Rectifiers Ltd
15-16 Woodbridge Meadows
Guildford,
Surrey. GU1 1BJ

Telephone: 01483 568281

Fax: 01483 504961

Email: david.neasham@t&r.co.uk

Background/ Reason for Issue


Supply of 33kV Auxiliary Transformer up to and including 500kVA for use in DC traction Sub-stations.

Network Rail action

Each party in the Network Rail supply chain receiving a product is responsible for ensuring conformance to specification.
Deficiencies in performance affecting the accepted functionality of the product or safety integrity identified by users of the product shall be reported in writing to Network Rail, HQ Acceptance Services.

For use by PADS agent: EC Interoperability

High Speed No Conventional No Declaration No. *


Acceptance Specialist



Network Rail
Acceptance National
Specialist team,
40 Melton Street
London. NW1 2EE

Certificate of Acceptance

Certificate No: PA05/01793 Issue: 1 Date: 14.03.06
Effective date: 14.03.06 Page 1 of 3

Product:	Substation Auxiliary Transformers. (Conforming to NR/SP/ELP/21020)
Manufacturer:	Transformers & Rectifiers Ltd 15-16 Woodbridge Meadows Guildford, Surrey. GU1 1BJ

The product above is accepted for use on the Network Rail infrastructure within the defined scope of acceptance and any specific conditions in the certificate.

Scope of Acceptance

Supply of 33kV Auxiliary Transformer up to and including 500kVA for use in DC traction Sub-stations.

Specific Conditions:

- Manufacturers and third party suppliers should take note of the requirements under Quality Assurance.
- Any deficiency affecting the product quality, functionality and safety integrity shall be notified in writing within 48 hours (including corrective action undertaken or proposed) to Network Rail Acceptance National Specialist Team.
- Manufacturers/Suppliers are responsible for ensuring that they are in possession of the latest relevant standards and/or drawings, and for ensuring that their products are compliant.
- Any proposed change to the product configuration (to the actual product or its application) shall be put forward in writing to Network Rail, Acceptance National Specialist Team.

Authorised by:


Kevin Lydford
Professional Head of Electrification & Plant, Engineering



Certificate of Acceptance

Certificate No: PA05/01793
Effective date: 14.03.06

Issue: 1 Date: 14.03.06
Page 2 of 3

QUALITY ASSURANCE

- This certificate has been issued according to the specific conditions of use.
- Each party in the Network Rail supply chain receiving a product is responsible for ensuring conformance to specification.
- The product acceptance certificate confirms that at the time of issue the product met the Network Rail acceptance requirements.
- The product acceptance certificate is not evidence that the product is maintained to specification post acceptance.
- The manufacturer and any third party suppliers of the product are responsible for ensuring conformance to specification.

PRODUCT CONFIGURATION

Part No.	Description	PADS No.
ONAN	Substation Auxiliary Transformers.	055/051016

ASSESSED DOCUMENTATION

Reference	Title	Date and Applies to Cert. issue No.	
-	PSU Product Acceptance submission	24.09.03	1

CERTIFICATE HISTORY

Issue Number	Date	Issue History
1	14.03.06	First accepted for use.



Certificate of Acceptance

Certificate No: PA05/01793 Issue: 1 Date: 14.03.06
Effective date: 14.03.06 Page 3 of 3

DISTRIBUTION

Manufacturer

Transformers & Rectifiers Ltd
15-16 Woodbridge Meadows
Guildford,
Surrey. GU1 1BJ
david.neasham@t&r.co.uk

Sponsor

Nick Jordan
Network Rail
PSU Project.

Agent

N/A

nick.jordan@networkrail.co.uk

For PADS records

Mark Coley
Serco Raildata Ltd, Derby
mcoley@serco.railtest.co.uk

PADS Input Agent
National Railway Supplies Ltd, Crewe
s.adams@natrail.com

For Information/briefing

Peter Agnew (Programme Manager
Maintenance Technology)
peter.agnew@networkrail.co.uk

Scott Mayle (Maintenance Technology
Analyst)
scott.mayle@networkrail.co.uk

WCRM
1 Eversholt Street, London
kapil.kara@networkrail.co.uk

Thameslink 2000
Friars Bridge Court, London
peter.harman@t12k.co.uk